WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71204
Permit No.
Basin 101

NOTICE OF INTENT NO. 39256

1. OWNER Dale Parr
MAILING ADDRESS 4200 Equestrian
Fallon Nv 89406

ADDRESS AT WELL LOCATION Same

2. LOCATION NE ¼ SW ¼ Sec. 16 T. 18 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) 006-171-25 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		6	10	10
Clay		10	14'	4
Sand		14	60	46

8. WELL CONSTRUCTION
Depth Drilled 60' Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10" Inches		0 Feet	60' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	18	5/16	0	60

Perforations:
Type perforation Slots
Size perforation ⅛ x 3"
From 55 feet to 60' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 60 feet

9. WATER LEVEL
Static water level 12' feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Farris Drilling (Contractor)
Address 1185 Pine Fallon 89406 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 043145
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2082
Signed (By driller performing actual drilling on site or contractor)
Date 4-29-98

Date started 4-10, 1998
Date completed 4-10, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
33	15'	4 HRS

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627