

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 71213
 Permit No. _____
 Basin 58

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35054

1. OWNER Claire Shaw ADDRESS AT WELL LOCATION Antelope Valley
 MAILING ADDRESS P.O. Box 988
Battle Mountain, NV 89820

2. LOCATION SE 1/4 NE 1/4 Sec. 16 T 25N N/S R 42E E Lander County
 PERMIT NO. 23921 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clay		260	275	15
Sand & gravel		275	280	5
Sandy clay		280	305	25
Sand & gravel		305	380	75
Clay		380	390	10
Sand & gravel		390	410	20
Clay		410	415	5
Sand & gravel		415	425	10
Sandy clay w/some gravel		425	460	35

8. WELL CONSTRUCTION
 Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)
 From 17 1/2 Inches 260 Feet 460 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>14</u>		<u>.250</u>	<u>160</u>	<u>460</u>

Perforations:
 Type perforation Mill slot
 Size perforation 1/8 x 3 Double row
 From 160 feet to 460 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Poured

Gravel Packed: Yes No
 From 180 feet to 460 feet

Date started 2/27/98, 19____
 Date completed 2/27/98, 19____

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.		

9. WATER LEVEL
 Static water level 160 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc.
 Contractor
 Address 4675 W. Winnemucca Blvd
 Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 3-13-98