WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71237
Permit No.
Basin 212

NOTICE OF INTENT NO. 17141

1. OWNER C.N.L.V. SANITATION DIVISION
MAILING ADDRESS 1003 E. BROOKS
NO. LAS VEGAS, NV 89030

ADDRESS AT WELL LOCATION A CHANNEL SEWER
INTERCEPTOR CHEYENNE TO OWNES
A CHANNEL SEWER PROJECT

2. LOCATION - ¼ - ¼ Sec. 30 T. 20S N/S R. 62 E. CLARK County
PERMIT NO. DW1074 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE dewater
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ABANDON 2 DEWATER | | | | |
| WELLS fill with 1 yard of | | | | |
| cement slurry. | | | | |
| excavated to depth, with | | | | |
| casings pulled & structure | | | | |
| built on top. | | | | |
| Well # 1 & 2. | | | | |

Date started 11/14/97, 19
Date completed 11/14/97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 29' Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 24" Inches | 0 Feet | 30' Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14 | 36.71 | .250 | -1 | 29 |
| | | | | |
| | | | | |

Perforations:
Type perforation Machine
Size perforation 1/4 x 2 1/2
From 20 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. VALLEY VIEW (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301
Signed Fred B. Allen Jr. (By driller performing actual drilling on site or contractor)
Date 2-13-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627