WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71242
Permit No.
Basin 105

NOTICE OF INTENT NO. 3274

1. OWNER CRC Construction Bob & Connie Scott
MAILING ADDRESS
ADDRESS AT WELL LOCATION 6400 [illegible] Run Stagecoach NV

2. LOCATION SW ¼ NE ¼ Sec. 7 T. 17 N/S R. 23 E. Lyon County
PERMIT NO. NA (Issued by Water Resources) 015-323-33 (Parcel No.) Iron Mtn. (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt, Boulders & Gravel		0	8'	8'
Cemented Boulders & Gravel		8	55'	47
Granite Rock		55	160'	105
Very Hard Granite		160	330	170
Broken Granite	✓	330	340	10
Hard Dense Granite	NA	340	500'	160
Hole pluged From 340 to 500' with Bentonite Hole Plug.				

RECEIVED 98 APR 20 AM 10:[illegible] STATE ENGINEERS OFFICE

Date started 3/24, 1998
Date completed 4/6, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3 GPM	4 Hr	Air Test

8. WELL CONSTRUCTION
Depth Drilled 500' Feet Depth Cased 340' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11" Inches	0 Feet	60 Feet
8 3/4 Inches	60 Feet	160' Feet
6" Inches	160 Feet	500' Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 5/8		188	+1	160
5"		188	152	340'

Perforations:
Type perforation Mill Slot
Size perforation 1/8 x 3
From feet to feet
From 330 feet to 340' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 180' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address Po. Box 599 (Contractor)
Silver Springs NV. 89479
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4/14/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627