

OFFICE USE ONLY  
Log No. 71262  
Permit No. 108  
Basin 108

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37773

1. OWNER Jeff Pope ADDRESS AT WELL LOCATION 11 Pana Vista Circle  
MAILING ADDRESS 11 Pana Vista Circle Yerington, Nv. 89417  
2. LOCATION SW 1/4 NE 1/4 Sec. 13 T. 12 QWS R 25 EAST LYON County  
PERMIT NO. 4-386-01 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown D.G		0	6	6
Brown Fine Sand		6	25	19
Brown clay w/multi colored coarse sand		25	40	15
Multi colored gravels		40	55	15
Multi colored volcanic rock (fractured)		55	65	10
Gray clay w/multi colored volcanic rock		65	70	5
Gray clay w/black volcanic rock		70	105	35
Rock fractured		105	120	15
Gray clay w/black volcanic rock		120	150	30
Rock fractured		150	160	10
Black volcanic rock fractured	x	160	185	25
Orange & black volcanic rock fractured	x	185	195	10

8. WELL CONSTRUCTION  
Depth Drilled 195 Feet Depth Cased 195 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
10 5/8 Inches 0 Feet 120 Feet  
8 1/2 Inches 120 Feet 195 Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1 1/2	195

Perforations:  
Type perforation Factory sawed  
Size perforation 3/32 x 3  
From 1.75 feet to 195 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
Depth of Seal 50'  Cement Grout  
Placement Method:  Pumped  Concrete Grout  
 Poured  
Gravel Packed:  Yes  No  
From 195 feet to 50 feet

9. WATER LEVEL  
Static water level 40' feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name A.S.A.P. Pump & Well Service Inc. Contractor  
Address P.O. Box 60130 Contractor  
Reno, Nevada 89506  
Nevada contractor's license number issued by the State Contractor's Board 35387-A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066  
Signed [Signature] By driller performing actual drilling on site or contractor  
Date March 17, 1998

Date started March 10, 1998  
Date completed March 13, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2 hrs</u>