



DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

OFFICE USE ONLY  
 Log No. 71281  
 Permit No. I 84  
 Basin. I 84

NOTICE OF INTENT NO. 35396

1. OWNER Tom C. & Lannette Pratt ADDRESS AT WELL LOCATION 6105 Whiskey Springs Road  
 MAILING ADDRESS 6105 Whiskey Springs Road 6105 Whiskey Springs Road  
Reno, NEVADA 89510 Reno, NEVADA 89510  
 2. LOCATION NW 1/4 NW 1/4 Sec. 4 T 22 N/S R 21 E AST WASHOE County  
 PERMIT NO. 077-430-02  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay with gravel stringer		293	295	2
Multi colored gravels		295	301	6
Brown clay with gravel stringer		301	304	3
Multi colored course sand with brown clay		304	315	11
Multi colored gravels	x	315	345	30
Brown clay with gravel stringer		345	351	6
Multi colored gravels with brown clay		351	359	8
Brown clay		359	365	6
Multi colored course sand		365	378	13
Brown clay		378	387	9
Brown clay with multi colored gravel stringer		387	420	33
Multi colored course sand	x	420	430	10
Multi colored gravels	x	430	500	70
T.D. 500'				

8. WELL CONSTRUCTION  
 Depth Drilled 500 Feet Depth Cased 500 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 5/8 Inches 0 Feet 500 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	+1 1/2	500

Perforations:  
 Type perforation Factory Sawn & Screen  
 Size perforation 3/32x3 Dbl, .050, 1/8 single  
 From 460 feet to 500, 1/8 sq1 feet  
 From 440 feet to 460, 3/32 dbl feet  
 From 420 feet to 440, screen feet  
 From 320 feet to 420, 1/8 sq1 feet  
 From 300 feet to 320, screen feet  
 Surface Seal:  Yes  No 300, 1/8 sq1 Seal Type:  
 Depth of Seal 170  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 500 feet to 170 feet

9. WATER LEVEL  
 Static water level 153 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. Pump & Well Service Inc. Contractor  
 Address P.O. Box 60130 Contractor  
Reno, NEVADA 89506  
 Nevada contractor's license number issued by the State Contractor's Board 35387-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date January 26, 1998

Date started January 2, 1998  
 Date completed January 13, 1998

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50+</u>		<u>14 Hrs.</u>