WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71300
Permit No.
Basin 72A

NOTICE OF INTENT NO. 37095

1. OWNER BRYANT GILKESON
MAILING ADDRESS 10425 Custer Road
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 10425 Custer Road
Reno, Nevada 89506

2. LOCATION NW ¼ SW ¼ Sec. 25 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 086-340-21 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	4	3
Brown fine sands		4	6	2
Brown sandy clays		6	34	28
Brown coarse sands		34	37	3
Brown sandy clays		37	56	19
Blue sandy clay		56	91	35
Dark blue-gray clay		91	112	21
Gray sands	X	112	115	3
Blue-gray clay		115	150	35

Date started 1-23-98, 19
Date completed 1-26-98, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	100 Feet
6 1/8 Inches		100 Feet	150 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	125
5		.188	120	150

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 100 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 foot
Placement Method: ☒ Pumped high static ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 125 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. 12 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date January 27, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627