

State Card # 34733

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY


STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 71310

Permit No.

Basin



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34733

1. OWNER Gene Miller ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO Box 1347 15626 _____
Trapper Point RD Sisters OR 97159 _____
 2. LOCATION SW 1/4 NE 1/4 Sec 24 T 1 (N/S R. 46 E. Nye County
 PERMIT NO. 31540 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	20	20
Sand & cemented G.		20	30	10
Hard clay & Gravel		30	40	10
Cemented Sand & Boulders		40	50	10
11 11 + Clay		50	60	10
pe gravel & Sand		60	75	15
Sand & Gravel w/ S Clay		75	130	60
Cemented Sand & Gravel		130	170	40
Sand & Gravel		170	205	35
Cemented Sand & Gravel		205	215	10
Sand & Gravel		215	255	40
Cemented Sand & Gravel		255	265	10
Sand & Gravel w/ S Clay		265	345	70
Sand & Gravel w/ S Clay & Shales		345	385	40
Cemented Sand & Gravel		385	395	10
Clay w/ S Gravel		395	410	15
Gravel		410	425	15
Clay		425	435	10

8. WELL CONSTRUCTION
 Depth Drilled 435 Feet Depth Cased 435 Feet
 HOLE DIAMETER (BIT SIZE)
 From 26 Inches To 435 Feet
 From 0 Feet To 435 Feet
 From _____ Inches To _____ Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16</u>		<u>.250</u>	<u>71</u>	<u>435</u>

Perforations:
 Type perforation Screen & Plug
 Size perforation 1/8 x 2 1/2 100% slot
 From 160 feet to 430 feet
 From _____ feet to _____ feet
 From 51.5 feet to _____ feet
 From Attachment feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal: 50 ft
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 435 feet

9. WATER LEVEL
 Static water level about 100 ft feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality Good

Date started 7-3, 1997
 Date completed 7-24, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>3000+</u>		<u>29</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name American Drilling & Pump Ser Contractor
 Address 3040 Callahan Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 20578
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1161
 Signed _____ by driller performing actual drilling on site or contractor
 Date 7-27-98

Casing Log

Well #1

