

Station card # 34734

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 7131
Permit No. 479
Basin
NOTICE OF INTENT NO. 34734

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Gene Miller ADDRESS AT WELL LOCATION _____
MAILING ADDRESS PO Box 1347 15676 Trapper
Front Rd. Sisters OR. 97759
2. LOCATION SW 1/4 NW 1/4 Sec 24 T 1 N 46 E County Wye
PERMIT NO. 31540 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>Sand Rock & Gravel</u>		<u>20</u>	<u>45</u>	<u>25</u>
<u>Sand & Gravel</u>		<u>45</u>	<u>75</u>	<u>30</u>
<u>Sand & Gravel</u>		<u>75</u>	<u>115</u>	<u>40</u>
<u>Cemented Gravel</u>		<u>115</u>	<u>165</u>	<u>50</u>
<u>Sand & Gravel</u>		<u>165</u>	<u>175</u>	<u>10</u>
<u>Cemented Sand & Gravel</u>		<u>175</u>	<u>185</u>	<u>10</u>
<u>Sand Gravel w/ clay</u>		<u>185</u>	<u>215</u>	<u>30</u>
<u>Sand</u>		<u>215</u>	<u>285</u>	<u>70</u>
<u>Cemented Gravel</u>		<u>285</u>	<u>295</u>	<u>10</u>
<u>Sand & Gravel w/ clay</u>		<u>295</u>	<u>370</u>	<u>75</u>
<u>Cemented Sand</u>		<u>370</u>	<u>380</u>	<u>10</u>
<u>Gravel & Sand</u>		<u>380</u>	<u>400</u>	<u>20</u>

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 400
26 Inches 0 Feet 400 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16</u>		<u>.250</u>		

Perforations:
Type perforation mill slot & screen
Size perforation 1/8 x 2 1/2 100 slot
From 140 feet to 400 feet
From see feet to _____ feet
From attachment feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 400 feet

9. 107 WATER LEVEL
Static water level at 7:10 AM feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality Good

Date started 7-26 1997
Date completed 8-18 1997


7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>3000+</u>		<u>32</u>
	<u>1100</u>	<u>129</u>	
	<u>2200</u>	<u>136</u>	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling & Pumping Co Contractor
Address 3040 Colleton Contractor
Winnemucca, NV 89445
Nevada contractor's license number 20578
issued by the State Contractor's Board
Nevada driller's license number issued by the 1161
Division of Water Resources, the on-site driller
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 8-27-98

Casing Log

Well #2



Vertical text on the left side of the page, possibly a scale or well depth indicator, is mostly illegible due to blurring and low resolution.