WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 7154
Permit No.
Basin 107

NOTICE OF INTENT NO. 27461

1. OWNER Lyon Co. School Dist.
MAILING ADDRESS 25 E. Goldfield Ave. Yerington, NV
ADDRESS AT WELL LOCATION Smith Valley High School #1 Day Lane, Smith Valley, NV

2. LOCATION SW ¼ NW ¼ Sec. 20 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. old no 854-B (Issued by Water Resources) APN# 10-501-01 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Augers

6. LITHOLOGIC LOG SVMW-9

Material	Water Strata	From	To	Thickness
I found well in good condition after pulling well cover / I drilling one casing to 15" the grout to surface				

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

Date started 4/18/97, 19
Date completed 4/18/97, 19

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8"	Inches	0 Feet	15 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	Sch 40	0	15

Perforations:
Type perforation Factory
Size perforation .020
From 5 feet to 15 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal 15
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andreesen Exploration Drilling (Contractor)
Address 1635 Belford rd. (Contractor)
Reno, NV 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8/20/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627