

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 71336  
 Permit No. 162  
 Basin T

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17626

1. OWNER **JAMES DUNN**  
 MAILING ADDRESS **3301 W. LAWRENCE PAHRUMP, NV 89048**  
 ADDRESS AT WELL LOCATION: **3301 W. LAWRENCE**

2. LOCATION **SE 1/4 SE 1/4 Sec. 24 T 20S** N/S **R 52E** E **NYE** County  
 PERMIT NO. **28-791-03** **CHARLESTON PARK RANCHOS**  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RV  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	65	65
CALICHE	WB	65	79	14
CLAY		79	92	13
CALICHE	WB	92	104	12
CLAY		104	119	15
CALICHE	WB	119	132	13
CLAY		132	140	8

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
12.25 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	140

Perforations:  
 Type perforation **FACTORY SAW CUT**  
 Size perforation **1/8" X 3"**

From <u>100</u>	feet to <u>120</u>	f
From _____	feet to _____	f
From _____	feet to _____	f
From _____	feet to _____	f
From _____	feet to _____	f

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 f



Date started 4/20/98 .19  
 Date completed 4/24/98 .19

9. WATER LEVEL  
 Static water level 59 feet below land surf  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)			Time (Hours)
	G.P.M.	Bailer <input type="checkbox"/>	Pump <input type="checkbox"/>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Great Basin Drilling Co.** Contractor  
 Address **PO BOX 4220** Contractor  
**PAHRUMP, NV 89041**  
 Nevada contractor's license number issued by the State Contractor's Board **30880**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**  
 Signed Thomas Dunn  
 By driller performing actual drilling on-site or contractor  
 Date 4/26/98

