WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71367
Permit No. 64454
Basin 211

NOTICE OF INTENT NO. 4269

1. OWNER Nevada Public Works Board
MAILING ADDRESS 505 East King St. Kinkead Bldg - Rm 301 - Carson City NV 89710
ADDRESS AT WELL LOCATION 1/4 Mile West of Hwy 95 + 2500' N. on Cold Creek Road (Well A)

2. LOCATION NW 1/4 NW 1/4 Sec. 33 T. 16 N/S R. 57 E. Clark County
PERMIT NO. W-2078 / 64454 Issued by Water Resources | 560-360-016 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse Silty Gravel w/Sand		0	50	50
Coarse Silty Gravel w/Sand		50	187	137
Poorly Graded Silty Sand		187	210	23
Silty Gravel w/Sand		210	271	61
Well Graded Sand		271	275	4
Poorly Graded Gravel w/Sand + Silt		275	427	52
Poorly Graded Sand		427	431	4
Poorly Graded Gravel w/Sand		431	446	15
Lean Clay		446	447	1
Poorly Graded Gravel w/Sand		447	455	8
Lean Clay		455	456	1
Poorly Graded Gravel w/Sand		456	465	9
Lean Clay		465	467	2
Poorly Graded Sand + Gravel		467	515	48
Clayey Gravel w/Sand		515	650	135
Poorly Graded Silty Gravel w/Sand		650	708	58
Gravelly Clay		708	712	4
Poorly Graded Gravel		712	768	56
Clayey Gravel		768	788	20
Poorly Graded Gravel w/Sand		788	875	87
Well Graded Clayey Sand		875	950	75
Poorly Graded Gravel		950	965	15
Well Graded Clayey Sand w/Gravel		965	995	30
Well Graded Gravel w/Sand		995	1027	32

MAY 27 1998

Date started 3-15, 19 98
Date completed 5-13, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
800	254.26	72

8. WELL CONSTRUCTION
Depth Drilled 1024' Feet Depth Cased 1002' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
30 Inches		0 Feet	50 Feet
22 Inches		50 Feet	1024 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	33.75	5/16	0	1002

Perforations:
Type perforation Roscoe Moss Full-Flo Louvers
Size perforation .100"
From 425 feet to 774 feet
From 815 feet to 964 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 1024 feet to 50 feet

9. WATER LEVEL
Static water level 201 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name B.L. Weber Group, Inc (Contractor)
Address 8108 Bay Harbor Drive (Contractor)
Las Vegas NV 89128
Nevada contractor's license number 041322 + 035639 issued by the State Contractor's Board.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2077
Signed Miles Frandsen (By driller performing actual drilling on site or contractor)
Date 5-18-98

(Rev. 1-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627