WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71364
Permit No. 64455
Basin 211
NOTICE OF INTENT NO. 16008

1. OWNER Nevada Public Works Board
MAILING ADDRESS 505 E. King St. Kinkead Bldg-Rm 301-Carson City NV 89710
ADDRESS AT WELL LOCATION Y4 Ring Well Hwy 95 + 2500' North of Cold Creek Road (Well B)

2. LOCATION SW ¼ NW ¼ Sec. 33 T. 16 S R. 57 E. Clark County
PERMIT NO. W-2078/64455 (Issued by Water Resources) 560-360-016 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Gravel w/Sand		0	50	50
~~[illegible]~~		~~[illegible]~~	~~[illegible]~~	~~[illegible]~~
Silty Gravel w/ Sand		50	85	35
Moderately Well Graded Gravel		85	100	15
Clayey Gravel		100	105	5
Moderately Well Cemented Gravel w/ Silty Sand		105	140	35
Sandy Clay w/Gravel		140	145	5
Well Graded Silty Gravel w/Sand		145	251	106
Poorly Graded Sandy Gravel w/ Silt + Sand		251	283	32
Well Graded Gravel w/Silt+Sand		283	449	166
Poorly Graded Sand w/Gravel		449	485	36
Clayed Sand w/Gravel		485	520	35
Sandy Gravel w/Silt		520	550	30
Well Graded Gravel w/Sand+Clay		550	819	269
Clayey Sand w/Gravel		819	895	76
Well Graded Gravel w/Clay+Sand		895	970	85
Cemented Clay w/Sand+Gravel		970	972	2
Well Graded Silty Gravel		972	980	8
Gravelly Clay w/Sand		980	985	5
Gravel w/Silt+Sand		985	1010	25

Date started 2-10, 19 98
Date completed 4-15, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1076	272.09	24

8. WELL CONSTRUCTION
Depth Drilled 1009 Feet Depth Cased 1002 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
30	0	50
22	50	1009

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	33.75	5/16	0	1002

Perforations:
Type perforation Roscoe Moss Fin-Flo Louvers
Size perforation .080
From 424 feet to 722 feet
From 764 feet to 962 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 1009 feet

9. WATER LEVEL
Static water level 235 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name B.L. Weber Group, Inc (Contractor)
Address 8108 Bay Harbor Drive (Contractor)
Las Vegas NV-89128
Nevada contractor's license number 041322 + 035639 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2077
Signed Miles Frandsen (By driller performing actual drilling on site or contractor)
Date 5-18-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627