


OFFICE USE ONLY
 Log No. 71365
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16919

1. OWNER James & Barbar Swallow ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 7731 Sandia Bluff 5941 Bridger St.
San Antonio, TX 78240 Pahrump, NV
 2. LOCATION NE 1/4 SE 1/4 Sec. 16 T. 21S N/S R. 54 E. Nye County
 PERMIT NO. 43-062-10 43-062-10 Cottonwoods, Unit 1, Block 8, Lot 10
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	2	2
Large gravel/clay		2	24	22
Brown clay		24	42	18
Rock & sand		42	56	14
Brown clay		56	80	24
Rocks & Clay	X	80	98	18
Cemented gravel		98	106	8
Brown clay		106	120	14
Cemented gravel		120	125	5
Brown clay	X	125	151	26
Cemented gravel		151	155	4
Brown Clay		155	180	25

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)
 From To
1.2 Inches 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17#	.188	0	180

Perforations:
 Type perforation Torch cut
 Size perforation 1/4 wide x 8" long
 From _____ feet to _____ feet
 From 140 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50'
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 180 feet

Date started 5-5-98, 19____
 Date completed 5-8-98, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	0	15 min

9. WATER LEVEL
 Static water level: 7.9 feet below land surface
 Artesian flow _____ G.P.M.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Well Drilling
Contractor

Address 1060 W. Basin Rd.
Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 7484
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725

Signed Charles Nyberg
By driller performing actual drilling on site or contractor

Date 5-22-98