


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 71371
 Permit No. 162
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17709

1. OWNER Earnest Reeves ADDRESS AT WELL LOCATION 4481 E. Martin
 MAILING ADDRESS 4481 E. Martin
Pahrump, NV 89048

2. LOCATION SE 1/4 NW 1/4 Sec. 29 T 21S N/S R 54E E Nye County
 PERMIT NO. 45-391-31 Parcel No. Fox Hollow Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown sandy loam		0	10	10
brown calache & rock		10	18	8
grey calache & rock		18	20	2
brown calache & rock		20	60	40
brown calache		60	64	4
brown sandy loam		64	70	6
brown sandy loam & rock		70	85	15
dark brown loam & gravel	x	85	110	25
brown sandy loam	x	110	129	19
brown sandy loam/gravel	x	129	150	21
brown calache	x	150	168	18
brown calache and rock	x	168	194	26
brown calache	x	194	200	6

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	200

Perforations:
 Type perforation SAW CUT
 Size perforation .188
 From 160 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 200 feet


9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 5/9/98 19____
 Date completed 5/9/98 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Bailer Draw Down (Feet Below Static)	Pump Time (Hours)	Air Lift Time (Hours)
	<u>.5</u>	<u>na</u>	<u>.50</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2089
 Signed [Signature]
 By driller performing actual drilling on-site of contractor
 Date 5-20-98



DCW
 MAY 26 1998