WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71448
Permit No.
Basin 69

NOTICE OF INTENT NO. 34354

1. OWNER Steve Baker
MAILING ADDRESS 3510 Delaney Dr
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 3325 Bronco Drive

2. LOCATION SE ¼ NE ¼ Sec. 16 T. 37 N/S R. 38 E. Humboldt County
PERMIT NO. N/A (Issued by Water Resources) 06-6041-06 (Parcel No.) Delaney Sub. (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Rock & Clay | | 0 | 35 | |
| Rock | | 35 | 55 | |
| Rock & Gravel | | 55 | 75 | |

Date started May 2, 19 98
Date completed May 3, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 15 | N/A | 4 hrs |

8. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 Inches | 0 Feet | 75 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | | .188 | +1 | 75 |

Perforations:
Type perforation Factory
Size perforation 1/8 by 3
From 55 feet to 75 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 75 feet to 50 feet

9. WATER LEVEL
Static water level 34 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Dave McNinch (Contractor)
Address 8005 McNinch Rd (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 5437
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5-5-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627