WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71464
Permit No.
Basin 69

NOTICE OF INTENT NO. 38414

1. OWNER Paradise Valley Fire District
MAILING ADDRESS Paradise Valley, NV

ADDRESS AT WELL LOCATION 605 South Main, Paradise Valley

2. LOCATION SE 1/4 SW 1/4 Sec. 25 T 42N N/S R 39E E Humboldt County
PERMIT NO. 63465T (Issued by Water Resources) 04-341-09 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill material		0	4	4
Clay		4	20	16
Cobbles		20	40	20
Sand & gravel		40	60	20
Sandy clay		60	70	10
Coarse sand 10% clay		70	110	40
Sandy clay		110	115	5
Sand		115	135	20
Sandy clay		135	143	8
Sand w/clay layers		143	250	107
Sand & gravel		250	270	20
Sand w/clay layers		270	370	100

RECEIVED JAN 16 1998 STATE ENGINEER'S OFFICE

Date started 1/7/98, 19__
Date completed 1/8/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
250	107'	5 hrs.

8. WELL CONSTRUCTION
Depth Drilled 370 Feet Depth Cased 370 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
20 Inches		0 Feet	370 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
3"			+2	110
12 3/4		.250	+2	120

Perforations:
Type perforation Double Mill slot
Size perforation .090
From 120 feet to 370 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 370 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 1-15-98