WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71474
Permit No.
Basin 84

NOTICE OF INTENT NO. 35399

1. OWNER Tehema Holdings Inc.
MAILING ADDRESS 100 W. Grove Street
Reno, Nevada 89509

ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SW ¼ Sec. 4 T. 22 N/S R. 21 EAST WASHOE County

PERMIT NO. (Issued by Water Resources) 077-340-45 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown D.G.		0	10	10
Brown clay with multi colored gravel stringer		10	15	5
Brown clay with multi colored sand		15	40	25
Brown clay		40	45	5
Multi colored gravels with course sand		45	50	5
Multi colored course sand		50	65	15
Brown clay with multi colored course sand		65	70	5
Brown clay with multi colored gravels		70	75	5
Brown clay with multi colored gravels & course sand		75	80	5
Multi colored course sand		80	90	10
Multi colored gravels with course sand		90	105	15
Multi colored gravels with brown clay		105	120	15
Brown sticky clay		120	123	3

-CONTINUED NEXT PAGE-

Date started January 15, 19 98
Date completed January 21, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
29	165.9	24 hrs.

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 5/8 Inches	0 Feet	250 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1½	250

Perforations:
Type perforation Factory sawed, Double perf
Size perforation 3/32 x 3
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 200
Placement Method: XX Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 250 feet to 200 feet

9. WATER LEVEL
Static water level 146.9 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Inc. (Contractor)
Address P.O. Box 60130 (Contractor)
Reno, NEVADA 89506

Nevada contractor's license number issued by the State Contractor's Board 35387-A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066

Signed Larry Welch (By driller performing actual drilling on site or contractor)
Date January 26, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71474
Permit No. 84
Basin

NOTICE OF INTENT NO. 35399

1. OWNER Tehema Holdings Inc.
MAILING ADDRESS 100 W. Grove Street
Reno, NEVADA 89509

ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SW ¼ Sec. 4 T. 22 N/S R. 21 EAST WASHOE County

PERMIT NO. (Issued by Water Resources) 077-340-45 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Multi colored gravels with course sand		123	130	7
Multi colored course sand		130	150	20
Multi colored sand & gravels		150	166	16
Brown stickey clay		166	170	4
Multi colored gravels with coures sand		170	182	12
Brown sticky clay		182	185	3
Multi colored course sand with large gravels	x	185	210	25
Brown sticky clay		210	211	1
Multi colored sand & gravel with brown clay	x	211	235	24
Multi colored course sand and gravels	x	235	250	15
T.D. 250'				

Date started January 15, 1998
Date completed January 21, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
29	165.9	24 hrs.

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 5/8 Inches	0 Feet	250 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	.188	+1½	250

Perforations:
Type perforation Factory sawed, double perf
Size perforation 3/32 x 3
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 200
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 250 feet to 200 feet

9. WATER LEVEL
Static water level 146.9 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Inc. (Contractor)
Address P.O. Box 60130 (Contractor)
Reno, NEVADA 89506

Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
Signed (By driller performing actual drilling on site or contractor)
Date January 26, 1998

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627