WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71520
Permit No.
Basin 104

NOTICE OF INTENT NO. 37842

Consultant:
1. OWNER SUMMIT ENVIROSOLUTIONS
MAILING ADDRESS 1475 Terminal Way, Suite B
Reno, Nevada 89502

Client:
ADDRESS AT WELL LOCATION SOUTHWEST GAS CORPORATION
250 So. Carson Street
Carson City, Nevada 89701

2. LOCATION NE ¼ NW ¼ Sec. 29 T 15N N/S R 20 E Carson City County
PERMIT NO. M/O 701 A & B SVE (Issued by Water Resources) 9-111-07 (Parcel No.) Carson City (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Static Water Level: 9 feet				
Total Depth: 21 feet				
1. measure SWL & TD				
2. Glue threaded adapter to existing casing				
3. Set tremie pipe to bottom of casing				
4. Pump neat cement fro bottom to surface approx 3/4 sack				
5. Pull tremie, fill casing & attach from cement pump directly to casing				
6. Pump cement @100 PSI sqeezing cement through perforation into surrounding formation, approx 3/4 sack				
When pressure increases, discontinue pumping				
Equipment:				
High pressure cement pump & mixer				
3/4 " dia tremie pipe				
Materials:				
Approx 1½ sacks Portland Cement Type II				
Location:				
Approx 25 feet South of Ben Franklin Craft Store in parking lot.				
1 well in a group of 14 wells				
Soil Vapor Extraction Wells				

Date started 2-23-98, 19
Date completed 2-23-98, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC				

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed (By driller performing actual drilling on site or contractor)
Date March 4, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627