

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **71561**
 Permit No. _____
 Basin **162**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **17733**

1. OWNER **Earnie Bozarth** ADDRESS AT WELL LOCATION **320 E. Gamebird**
 MAILING ADDRESS **320 E. Gamebird**
Pahrump, NV 89048

2. LOCATION **SE 1/4 SW 1/4 Sec. 34 T 20S N/S R 53E E Nye** County
 PERMIT NO. **40-702-12** Parcel No. **Calvada Valley** Subdivision Name

Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	19	19
grey calache		19	32	13
brown calache		32	41	9
brown clay		41	60	19
brown calache/clay strings	x	60	83	23
brown calache	x	83	118	35
brown calache	x	118	123	5
See next line	x	123	140	17
brown calache/brown clay strings				

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)
 From To
11 Inches **0** Feet **140** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
 Type perforation **Saw Cut**
 Size perforation **.188**


From **100** feet to **140** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal **50**

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From **0** feet to **140** feet



Date started **5/23/98**, 19____
 Date completed **5/23/98**, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
.5	na	.50	

9. WATER LEVEL
 Static water level **60** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cold** °F Quality **good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *[Signature]*
 By driller performing actual drilling on-site or contractor

Date **6-2-98**

