

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 71570
 Permit No. 212/62
 Basin 212/62

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17239

1. OWNER George & Shirley Rossner ADDRESS AT WELL LOCATION 3391 W. Shadow Mt. St.
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SE 1/4 Sec 1 T. 20-S N/S R. 52 E Nye County
 PERMIT NO. 28-422-04 Vegas Acres Ut. 1
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Gray Clay		4	28	24
Green Clay		29	39	11
Gray Clay		39	58	19
Gray Clay/caliche	x	58	74	16
Brown Clay		74	96	22
Brown Clay/caliche		96	108	12
Brown Clay	x	108	131	23
Brown Clay/caliche		131	140	9

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>12</u> Inches	<u>0</u> Feet <u>140</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.04</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Torch Cut
 Size perforation 1/4" width 8" long
 From 100 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 38 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started May 27 1998
 Date completed May 27 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>4</u>	<u>1/2</u>

Name Jim Pike Well Drilling, LLC. Contractor
 Address P.O. Box 56 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 17563A
 Nevada driller's license number issued by the Division of Water Resources 1812 the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date May 29, 1998