

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. **71575**
 Permit No. _____
 Basin **162**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 6921

1. OWNER Kirby G. Jamison ADDRESS AT WELL LOCATION 300 S. Margaret St.
 MAILING ADDRESS 300 S. Margaret St. Pahrump, NV 89048
 2. LOCATION NW 1/4 NW 1/4 Sec. 16 T. 20S N/S R. 53 E Nye County
 PERMIT NO. 35-331-50 Parcel No. 35-331-50 Subdivision Name Flora Vista Lot 4

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Grey clay		4	12	8
Brown clay		12	60	48
Hard limestone		60	66	6
Soft brown clay	X	66	80	14
Hard lime		80	85	5
Brown clay	X	85	112	37
Hard lime		112	117	5
Brown clay	X	117	132	5
Hard lime		132	135	3
Brown clay	X	135	160	25

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 160 Feet
 " _____ Inches _____ Feet _____ Feet
 " _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17.4	.188	0	160

Perforations:
 Type perforation Torch cut
 Size perforation 1" wide x 8" long
 From _____ feet to _____ feet
 From 120 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 5.0'
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 5.0 feet to 160 feet

9. WATER LEVEL
 Static water level: 4.3 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Well Drilling Contractor
 Address 1060 W. Basin Rd. Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board: 7484

Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 725

Signed Charles Nyberg
 By driller performing actual drilling on site or contractor

Date 6-4-98

Date started 5-27-98 19____
 Date completed 5-29-98 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	0	15 min