


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. **71586**  
 Permit No. \_\_\_\_\_  
 Basin **162**



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **17638**

1. OWNER **YATES** ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS **3551 S. UNICORN** **3551 S. UNICORN**  
**PAHRUMP, NV 89048**

2. LOCATION **NW 1/4 SW 1/4 Sec. 35 T 20S** N/S **R 53E E NYE** County \_\_\_\_\_  
 PERMIT NO. **41-121-02** **CALVADA VALLEY** Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RV  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	58	58
CALICHE	WB	58	70	12
CLAY		70	88	18
CALICHE	WB	88	105	17
CLAY		105	118	13
CALICHE	WB	118	135	17
CLAY		135	140	5

8. WELL CONSTRUCTION  
 Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 140  
**10.25** Inches 0 Feet **140** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0	140

Perforations:  
 Type perforation **SAW CUT**  
 Size perforation **1 7/8" X 3"**

From **100** feet to **140** f  
 From \_\_\_\_\_ feet to \_\_\_\_\_ f

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **50**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **140** f

Date started **5/11/98** \_\_\_\_\_, 19\_\_\_\_  
 Date completed **5/15/98** \_\_\_\_\_, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)			Time (Hours)
	G.P.M.	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	
		<input type="checkbox"/> Air Lift		

9. WATER LEVEL  
 Static water level **52** feet below land surf  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Great Basin Drilling Co.** Contractor  
 Address **PO BOX 4220** Contractor  
**PAHRUMP, NV 89041**

Nevada contractor's license number issued by the State Contractor's Board **30880**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**

Signed *Thomas D. ...*  
 By driller performing actual drilling on-site or contractor  
 Date **5/27/98**

