

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 71589
 Permit No. 84
 Basin 6307HE

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33903
 Client: BOEING NORTH AMERICAN, INC.

Consultant: CDM ENGINEERS & CONSTRUCTORS, INC.
 1. OWNER CDM ENGINEERS & CONSTRUCTORS, INC. ADDRESS AT WELL LOCATION BOEING NORTH AMERICAN, INC.
 MAILING ADDRESS 50 West Liberty St. Suite 770 Rocketdyne Former Field Lab - Area C,
Reno, Nevada 89501 Palomino Valley, NV
 2. LOCATION NW 1/4 SE 1/4 Sec. 18 T. 22N N/S R. 22 E Washoe County
 PERMIT NO. M/O 1142 CEX-3 077-310-10 Area - C Palomino Valley
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Dry, loose, brown gray fine sand, some silt, little gravel, slow drilling to 5 feet		0	5	5
Med. dense, brown gray sand, some gravel & silt water injected @5 feet		5	12	7
Med. dense brown gray sand & gravel, some silt, little clay		12	25	13
As above, med. dense, wet below 25 ft., no water injected @25 ft.		25	33	8
Wet, soft, brown gray clay, some gravel, little sand		33	42	9
Wet med. dense, Gravel some clay, little sand		42	50	8
As above, med. dense, little clay below 50 ft		50	52	2
Wet med. dense, brown gray, Tuff, fresh, med. hard, slightly weathered phenocrysts of hornblende & plagioclase		52	54.70	2.70

8. WELL CONSTRUCTION
 Depth Drilled 54.70 Feet Depth Cased 54.20 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 54.70 Feet
 From 0 Inches To 0 Feet 0 Feet
 From 0 Inches To 0 Feet 0 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6" PVC		sch 80	-2	14.20

 Threaded Stainless Steel End Cap, Traffic-rated Steel Well Vault
 Perforations:
 Type perforation SS Wire Wrapped Screen
 Size perforation 0.020
 From 14.20 feet to 54.20 feet
 From 0 feet to 0 feet
 From 0 feet to 0 feet
 From 0 feet to 0 feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 3 - 7.90 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Bentonite Seal: 7.90 to 9.70
 Gravel Packed: Yes No #3 Lonestar Sand
 From 9.70 feet to 54.70 feet

9. WATER LEVEL
 Static water level 25.90 feet below land surface
 Artesian flow G.P. not known P.S.I.
 Water temperature cold °F Quality not known

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 908
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date April 6, 1998

7. WELL TEST DATA
 METHOD: Bailer Pump Air Lift

No test	Draw Down (Feet Below Static)	Time (Hours)

 Date started 8-20-97, 19.....
 Date completed 8-20-97, 19.....
Plugged by well log No. 116209

RECEIVED
 APR 13 AM 10:42
 STATE ENGINEERS OFFICE