WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71630
Permit No.
Basin 108

NOTICE OF INTENT NO. 37611

1. OWNER William Giles
MAILING ADDRESS 131 N. Hwy 95 A
Yerington Nev 89447

ADDRESS AT WELL LOCATION #3 E. Alder Drive
Yerington Nev 89447

2. LOCATION SW ¼ SE ¼ Sec. 29 T. 14 N/S R. 25 E. Lyon County

PERMIT NO. ..... Issued by Water Resources | 14-271-60 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvial brown Soil Small Rock		0	52	52
Coarse Sand + gravel	yes	52	65	13
Sandy Clay	yes	65	110	45
Coarse Sand + pea gravel	yes	110	140	30

RECEIVED
98 APR 27 AM 10:58
STATE ENGINEERS OFFICE

Date started 3-28-, 1998
Date completed 4-8-, 1998

7. WELL TEST DATA

TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	5 ft	3 Hrs

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		188	0	140

Perforations:
Type perforation ~~Saw~~ Factory saw slott
Size perforation 3-32 x 3
From 120 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow ..... G.P.M. ..... P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller
Contractor
Address P.O. Box 92
Contractor
Smith, Nev 89430
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller
By driller performing actual drilling on site or contractor
Date 4-24-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627