WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71635
Permit No.
Basin 88

NOTICE OF INTENT NO. 38011

1. OWNER Randy Ritter
MAILING ADDRESS 15835 Caswell Lane
Reno, NV 89511

ADDRESS AT WELL LOCATION 15835 Caswell Lane Reno, NV

2. LOCATION SW 1/4 SE 1/4 Sec. 34 T 18N N/S R 19E E Wasehoe County
PERMIT NO. WaCo #5962 (Issued by Water Resources) 049-080-15 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay and top soil		0	5	5
Cemented gravels w/ Bldrs		5	150	145
Cemented gravels		150	160	10
Small dark gravels	x	160	195	35
Larger black gravels	x	195	228	33

Date started 11/3/97, 19__
Date completed 11/5/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased 228 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	160	Feet
8 5/8	Inches	160	Feet	230	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	228

Perforations:
Type perforation Factory
Size perforation 3/32" x 3" single row
From 208 feet to 228 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 150
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout [X] BEN SEAL
Gravel Packed: [X] Yes [ ] No
From 150 feet to 228 feet

9. WATER LEVEL
Static water level 106 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 11-20-97

Deepened by weld log 123799