WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71637
Permit No.
Basin 72

NOTICE OF INTENT NO. 38410

1. OWNER Burns Bros. Truck Stop/Pat Jameson
MAILING ADDRESS 516 SE Morrison Suite 1200
Portland, OR 97214

ADDRESS AT WELL LOCATION
Mill City, NV

2. LOCATION NW 1/4 SW 1/4 Sec. 33 T 33N N/S R 35E E Pershing County
PERMIT NO. | Issued by Water Resources | 008-130-01 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [✓] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel		0	3	3
Cemented sand & gravel		3	94	91
Clay		94	101	7
Cemented sand & gravel	x	101	125	24

RECEIVED 97 DEC 10 AM 10:46 STATE ENGINEER'S OFFICE

Date started 12/2/97, 19__
Date completed 12/3/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 115.5 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	0	Feet	125	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 3/8		Sch.80	+2	115.5

Perforations:
Type perforation Slot
Size perforation .020
From 85.5 feet to 105.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 76
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 80 feet to 125 feet

9. WATER LEVEL
Static water level 91.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed Jerry A. Jongk
(By driller performing actual drilling on-site or contractor)

Date 12-4-97