WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71643
Permit No.
Basin 92A

NOTICE OF INTENT NO. 37097

1. OWNER STEVEN K. CURL
MAILING ADDRESS 7665 Hill View Drive
Reno, Nevada 89506

ADDRESS AT WELL LOCATION Adobe Drive
Reno, Nevada 89506

2. LOCATION NW ¼ NW ¼ Sec. 13 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 082-060-17 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	9	8
Brown sandy clay		9	16	7
Brown clay		16	61	45
Brown sandy clay		61	121	60
Granite sands		121	123	2
Brown sandy clay		123	169	46
Granite sands (NO WATER)		169	170	1
Brown sandy clay		170	223	53
Brown clay		223	283	60
Granite sands	X	283	301	18
Brown clay		301	311	10
Granite sands		311	321	10
Brown clay		321	325	4

Date started 4-8-98, 19
Date completed 4-10-98, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		

8. WELL CONSTRUCTION
Depth Drilled 325 Feet Depth Cased 325 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	325	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	325

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 280 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 325 feet

9. WATER LEVEL
Static water level 240 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed (By driller performing actual drilling on site or contractor)
Date April 10, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627