

OFFICE USE ONLY
 Log No. 71654
 Permit No. 92A
 Basin 92A

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37845

1. OWNER RURAL TELEPHONE COMPANY ADDRESS AT WELL LOCATION 1305 Antelope Valley Road
 MAILING ADDRESS P.O. Box 969/704 Madison Ave Reno, Nevada 89506
Glenns Ferry, ID 83623
 2. LOCATION NE 1/4 NE 1/4 Sec. 33 T 22N N/S R. 19 E Washoe County
 PERMIT NO. 079-420-23 Antelope Valley Red Rock Est #5221
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Decomposed granite		1	16	15
Gray weathered granite		16	61	45
Rusty decomposed granite		61	72	11
GRay granite		72	119	47
Hard gray granite		119	173	54
Weathered green granite		173	221	48
Gray hard granite		221	365	144
Fracture (app 3 GPM)	X	365	366	1
Gray granite weathered		366	373	7
Fracture granite	X	373	435	62
Gray granite		435	450	15

8. WELL CONSTRUCTION
 Depth Drilled 450 Feet Depth Cased 450 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 50 Feet
 8 5/8 Inches 50 Feet 450 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	450

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 365 feet to 385 feet
 From 405 feet to 445 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50 feet
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 450 feet

9. WATER LEVEL
 Static water level 325 feet below land surface
 Artesian flow _____ G.P.M. 20 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date April 20, 1998

Date started 4-15-98, 19____
 Date completed 4-17-98, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		

RECEIVED
 30 APR 22 AM 10:00
 STATE ENGINEER'S OFFICE