WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71664
Permit No.
Basin 105

NOTICE OF INTENT NO. 30021

1. OWNER Gardnerville Town Water Co.
MAILING ADDRESS 1390 HWY 395 North
Gardnerville, NV. 89410

ADDRESS AT WELL LOCATION Near hwy 395
by Gardnerville Post Office

2. LOCATION NW ¼ SW ¼ Sec. 3 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. 26323 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Original well drillers report claimed well was 200' deep with 10" casing and perforations were from 70' to 200' Bailed well to a depth of 192' where all we could retrive was clay. Decided the well was set with open bottom and 192 was total depth. Placed 2" tremme pipe to a depth of 189' and pumped 4 cubic yards of neat cement in well from bottom up. Casing was cut-off 2" below ground surface and covered. Spoke with Mat Dillion and decided that since there was only 15' of blank casing between the cement seal and the perforations, that it was not necessary to perforate the blank casing.				

Date started 3-30, 19 98
Date completed 3-30, 19 98

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0 to 192'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address 1401 North Roop, (Contractor)
Carson City, NV. 89701
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Trompe (By driller performing actual drilling on site or contractor)
Date 3/31/98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627