

OFFICE USE ONLY
 Log No. 71665
 Permit No. 6A096 6A196
 Basin 705

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37892

1. OWNER Douglas County
 MAILING ADDRESS P.O. Box 218
 Minden, NV 89423
 ADDRESS AT WELL LOCATION 1/4 mile North of
 Johnson Lane, 100 feet East of Heybourn
 Road
 2. LOCATION NW 1/4 SE 1/4 Sec. 32 T. 14 N S R. 20 E Douglas County
 PERMIT NO. W-491-A 21-290-56
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	8	8
Fine Sand		8	40	32
Fine Sand & Gravel		40	140	100
Gray Clay & Gravel		140	211	71
Fine Sand & Gravel		211	320	109
Coarse Sand & Gravel		320	420	100
Fine Sand, Gravel, Tr. Clay		420	451	31
Green Clay		451	466	15

8. WELL CONSTRUCTION
 Depth Drilled 466 Feet Depth Cased 446 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 466 Feet
 28 Inches
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	52.36	.312	+4	106
16	52.36	.312	146	210
16	52.36	.312	290	356
16	52.36	.312	436	446

Perforations: Houston ss pipe based
 Type perforation .055 slot
 Size perforation .055 slot
 From 106 feet to 146 feet
 From 210 feet to 290 feet
 From 356 feet to 436 feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 100 feet Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 446 feet

9. WATER LEVEL
 Static water level 13 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature 68 °F Quality Good

Date started February 4, 1998
 Date completed April 3, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	1200	58.4	8

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sargent Irrigation Company
 Contractor
 Address 9955 North Virginia Street
 Contractor
 Reno, Nevada 89506
 Nevada contractor's license number 0021246
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1413
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date April 10, 1998

RECEIVED
 28 APR 15 AM 10:25
 STATE ENGINEERING DIVISION