WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71669
Permit No.
Basin 105

NOTICE OF INTENT NO. 36763

1. OWNER Hearthside Homes
MAILING ADDRESS
ADDRESS AT WELL LOCATION 2209 Calle Hermosa

2. LOCATION NW ¼ SW ¼ Sec. 32 T. 12 N/S R. 21 E. Douglas County
PERMIT NO. (Issued by Water Resources) 23-180-46 (Parcel No.) Fish Springs (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Boulders		0	3	3
D G		3	27	24
Sand & ~~Gravel~~		27	38	11
Sand & Gravel		38	59	11
Clay		59	62	3
Sandy Clay		62	94	32
Sand & Gravel		94	116	22
Sandy Clay		116	132	36
Sandy Clay & Gravel		132	157	25
Sand & Gravel	✓	157	182	25
Clay		182	185	3

RECEIVED 98 APR 24 AM 10:07 STATE ENGINEER'S OFFICE

Date started 4-13, 1998
Date completed 4-18, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1½ hrs

8. WELL CONSTRUCTION
Depth Drilled 185 Feet Depth Cased 185 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	60 Feet
9 7/8 Inches		60 Feet	185 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	.13	188	-1	185

Perforations:
Type perforation Factory mill
Size perforation 3/16 x 4
From 165 feet to 185 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 50 feet to 185 feet

9. WATER LEVEL
Static water level 99' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc (Contractor)
Address 7780 Curry Rd (Contractor)
Fallon, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 586
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-20-98

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627