WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71672
Permit No.
Basin 105

NOTICE OF INTENT NO. 36052

1. OWNER DONALD E. BENTLEY
MAILING ADDRESS P.O. BOX 127
MINDEN, NV 89423

ADDRESS AT WELL LOCATION SOUTH RANCH
Bentley Agra Dynamics
Minden, NV

2. LOCATION SE ¼ NW ¼ Sec. 29 T. 12 (N)/S R. 20 E. DOUGLAS County
PERMIT NO. 62819 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY AND COBBLES		0	6	6
SAND AND COBBLES		6	15	9
COARSE SANDS AND ROCK		15	30	15
BLACK, BROWN ROCK		30	70	40
BLACK, BROWN, WHITE ROCK		70	87	17
SANDY CLAYS		87	110	23
SAND, BLACK ROCK CLAY LENSES		110	130	20
BLACK ROCK, SAND AND CLAY		130	150	20
BLACK ROCK, SAND, GRAVEL		150	185	35
HARD SAND AND GRAVEL		185	190	5
ROCK, SAND, BLACK ROCK		190	200	10
SAND, ROCK, GRAVEL		200	210	10

Date started NOVEMBER 25, 19 97
Date completed DECEMBER 2, 19 97

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
85		4.5

8. WELL CONSTRUCTION
Depth Drilled 210 Feet Depth Cased 202 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
14 3/4	0	210

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.79	.188	+2	202

Perforations:
Type perforation MILL SLOT
Size perforation 3" X 1/8"
From 102 feet to 182 feet
From 182 feet to 202 ~~LOWERED~~ feet
From feet to Louvered feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 210 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION COMPANY (Contractor)
Address 9955 NORTH VIRGINIA STREET (Contractor)
RENO, NEVADA 89506
Nevada contractor's license number issued by the State Contractor's Board 0021264
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1593
Signed (By driller performing actual drilling on site or contractor)
Date DECEMBER 1, 1997

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627