WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71693
Permit No.
Basin 103

NOTICE OF INTENT NO. 36265

1. OWNER Steve Coté
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1079 Porter Lane Gardnerville NV.

2. LOCATION NE ¼ SE ¼ Sec. 12 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. 23-234-11 Subdivision Name Sagewood

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other
4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock
5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay & Boulders		0	43	43
Sand Gravel & Boulders		43	67	24
Sandy Clay		67	71	4
Sand & Gravel		71	168	97
Sandy Clay		168	192	24
Sand & Gravel		192	209	17
Clay		209	226	17
Sand & Gravel		226	247	21
Clay		247	255	8
Sand & Gravel		255	271	16
Clay		271	277	6
Sand Gravel Cobbles	✓	277	296	19
Gravel & Basalt Cobbles	✓	296	420	124

Date started Dec 9, 1997
Date completed Dec 11, 1997

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1.00

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 420 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	50 Feet
9 7/8 Inches	50 Feet	420 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	450

Perforations:
Type perforation Factory Mill
Size perforation 18 x 4 14 Row
From 400 feet to 420 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 420 feet

9. WATER LEVEL
Static water level 255 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddie Exploration Inc (Contractor)
Address 7780 Curry Rd (Contractor)
Fallon NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed (By driller performing actual drilling on site or contractor)
Date Dec 22 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627