WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71680
Permit No.
Basin 104

NOTICE OF INTENT NO. 31623

1. OWNER Silver Oak Development
MAILING ADDRESS 3075 College Dr
Carson City, NV 89701
ADDRESS AT WELL LOCATION Hole 17 Green Golf Course

2. LOCATION SE ¼ SW ¼ Sec. 6 T. 16/5 N/S R 20 E. Carson City County
PERMIT NO. (Issued by Water Resources) 8-061-40 (Parcel No.) Silver Oak (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Const Fill | | 0 | 3 | 3 |
| Silty Loam | | 3 | 5 | 2 |
| Alternating Sands, Silt, Some V Small Grvl, Thin Bedded Clayey Sands, Water Zones V Soft | | 5 | 250 | 245 |

Date started 9/11, 1997
Date completed 9/14, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 50+ | | 5 |

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 9⅞ | 0 | 250 |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.5 | 2 | .474 | +2 | 25 |
| | PVC Sch 40 | | | |

Perforations:
Type perforation Slots
Size perforation 0.020
From 55 feet to 245 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 245 feet

9. WATER LEVEL
Static water level 43 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 61 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Drilling, Inc (Contractor)
Address 75 Lewers Crk Rd (Contractor)
Carson City, NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Leisch (by driller performing actual drilling on site or contractor)
Date 9/24/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627