

OFFICE USE ONLY
 Log No. 71681
 Permit No. 104
 Basin 34416

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34416

1. OWNER CARSON CITY UTILITIES DEPT. ADDRESS AT WELL LOCATION GOLF COURSE AT CHARCOBWAY
 MAILING ADDRESS 3505 BUTTE WAY
CARSON CITY, NV 89701

2. LOCATION NE 1/4 NW 1/4 Sec. 7 T. 15 S. R. 20 E. CARSON CITY County
 PERMIT NO. TNEV 97025 Issued by Water Resources Parcel No. NONE Subdivision Name SILVER OAKS

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CONSTRUCTION FILL		0	2	2
COMPACTED SILTY LOAM		2	4	2
ALTERNATING SANDS, SILTS + V THIN BROWN CLAYS, V MINER SMALL (1/4) GRVLS. DG FROM 2 TO 250 FT		4	250	246
VERY SOFT IN WATER ZONES				
GRAVEL FILL TUBE TO 58 FT				

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 250 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>2</u>	<u>.474</u>	<u>+2</u>	<u>250</u>
PVC SCH <u>40</u>				

Perforations:
 Type perforation SLITS
 Size perforation .020
 From 55 feet to 245 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 55 feet to 250 feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow NO G.P.M. P.S.I.
 Water temperature 61° Quality

Date started 9/5, 1997
 Date completed 9/9, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50+</u>		<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING, INC Contractor
 Address 75 LEWERS CRK RO Contractor
CARSON CITY, NV 89704
 Nevada contractor's license number issued by the State Contractor's Board 13697A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed Joe Reich
 Driller performing actual drilling on site or contractor
 Date 9/24/97