

OFFICE USE ONLY
 Log No. 11676/71697
 Permit No. 1
 Basin. 1
 NOTICE OF INTENT NO. 37548

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Barrick Goldstrike, Inc. ADDRESS AT WELL LOCATION Barrick Goldstrike Mine Site
 MAILING ADDRESS P.O. Box 29 Elko, NV 89803 GWOP-7C
 2. LOCATION SE 1/4 NW 1/4 Sec 29 T. 36N N/S R. 50 E Eureka County
 PERMIT NO. M10-233C? Tract of Land
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
3/4 Gravel		0	20	20
Gravel & Clay		20	65	45
3/4 Gravel Sand		65	125	60
Hard Rock		125	155	30
Frac Rock, Gravel Sand		155	210	55
Hard Rock		210	260	50
Hard Rock & Sand		260	300	40
1/2 Rock & Sand		300	365	65
Hard Rock		365	400	35
Dry Hole				

Hole Abandoned by mixing 16 bags of Abandonite with 600 gallons of water & pumping down hole, then put 12 bags of 3/8 hole plug on top, bring it up to within 10 feet of the surface then used 3 bags of cement for a 10' seal

RECEIVED
 99 MAY -4 AM 10:58
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 0 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 400 Feet
8 1/2 Inches
 Inches Feet Feet Feet
 Inches Feet Feet Feet
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation.....
 Size perforation.....
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal.....
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From..... feet to..... feet

9. WATER LEVEL
 Static water level Dry Hole feet below land surface
 Artesian flow..... G.P.M. P.S.I.
 Water temperature..... °F Quality.....

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Hackworth Drilling, Inc.
 Address P.O. Box 850
Elko, NV 89803
 Nevada contractor's license number 020582
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1395
 Division of Water Resources, the on-site driller
 Signed George M. Alkham
 By driller performing actual drilling on site or contractor
 Date 5/1/98

Date Started Mar. 25, 98
 Date completed Mar. 27, 1998

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>0</u>	<u>0</u>	<u>0</u>