WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41700
Permit No.
Basin

NOTICE OF INTENT NO. 39071

1. OWNER Gilbert Cloyd
MAILING ADDRESS 8115 Mohawk
Reno, NV 89506

ADDRESS AT WELL LOCATION
8115 Mohawk

2. LOCATION NE 1/4 NE 1/4 Sec. 17 T 20N N/S R 19E E Washoe County
PERMIT NO. Wa Co#6119 (Issued by Water Resources) | 82-225-04 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the well				
by perforating from bottom to 300'				
using a Mills Knife perforating				
tool. We then pumped				
approximately 4.5 yards of neat				
cement at 5.2 gallons water per				
sack of cement using tremie tube				
from bottom to top of casing. We				
cut the top 2' off top of casing.				

Date started 4/24/98, 19__
Date completed 4/24/98, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 476 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
____	Inches	____ Feet	____ Feet
____	Inches	____ Feet	____ Feet
____	Inches	____ Feet	____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	476

Perforations:
Type perforation Mills Knife
Size perforation
From 300 feet to 476 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 367 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor

Date 5-15-98