WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71703
Permit No. 923
Basin 123

NOTICE OF INTENT NO. 35043

1. OWNER Sherwin-Williams
MAILING ADDRESS 101 Prospect Avenue, N.W.
Cleveland, OH 44115-1075

ADDRESS AT WELL LOCATION
1/4 mile E. Military Rd., Stead, NV

2. LOCATION NW 1/4 SE 1/4 Sec. 33 T 21N N/S R 19E E Washoe County
PERMIT NO. 61588 Issued by Water Resources | 61590 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel		0	46	46
See next line		46	137	91
Interbedded clay sand/grvel beds				
See next line		137	197	60
Interbedded sand & gravelly sand w/gravel & clay				
Clay w/thin sand beds		197	231	34
See next line		231	360	129
Sand w/thin gravel & clay beds				
See next line		360	393	33
Clay w/occasional sand or gravel beds				
Gravelly sand		393	417	24
Sandy clay to clayey sand		417	437	20
Sand & gravel		437	492	55
Sandy siltstone		492	500	8

Date started 10/21/97, 19__
Date completed 10/25/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
437	144.6	72 hrs.

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
32	Inches	0	Feet	34	Feet
21 1/2	Inches	34	Feet	500	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4		1/4	0	460

Perforations:
Type perforation Johnson wire wrap
Size perforation # .80
From 230 feet to 240 feet
From 260 feet to 360 feet
From 395 feet to 415 feet
From 435 feet to 455 feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 210
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 216 feet to 500 feet

9. WATER LEVEL
Static water level 79.25 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1572

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 12-9-97