


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



OFFICE USE ONLY

Log No. 71707-71711  
 Permit No. \_\_\_\_\_  
 Basin 100

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36895

1. OWNER Roston Company, L.L.C. ADDRESS AT WELL LOCATION Reno Parks Blvd - 1450 Mud Springs Road  
 MAILING ADDRESS 300 Carlsbad Village Drive  
Carlsbad, Ca 92008

2. LOCATION NE 1/4 NE 1/4 Sec. 20 T. 21N N/S R. 18 E MDB+M County Gold Springs Valley Waste Water Treatment Plant  
 PERMIT NO. PWPWA 96375 DEW-0094, B Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED DW-05 4. PROPOSED USE dewater 5. WELL TYPE

New Well  Replace  Recondition  Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Deepen  Abandon  Other Destruction  Municipal/Industrial  Monitor  Stock  Air  Other Bucket Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Purpose of Report -				
Destroy 23 Temporary Dewatering Wells -				
All casings extracted, allowing the gravel filter to drop to 6' or more - at least 2' below static water level. Those that did not drop the required depth were dug out with a small bucket backhoe - We pumped the static water level down on each well and filled with 5 sack grout to the existing surface grade.				
The above is all <del>xxx</del> in accordance with a letter dated May 16, 1997 from Thomas K. Gallagher, P.E. Hydraulic Engineer III				

8. WELL CONSTRUCTION

Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>30</u> Inches	<u>40</u> Feet
_____ Inches	_____ Feet
_____ Inches	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>XXXX</u>				

Perforations:

Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level: 3.8 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 5-29-97, 19\_\_\_\_\_  
 Date completed 5-29-97, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Joseph E. Myhren, Jr.  
 Address 801 Northport Drive W. Sacramento, Ca. 95691  
 Contractor \_\_\_\_\_  
 Contractor \_\_\_\_\_

Nevada contractor's license number 0044407  
 issued by the State Contractor's Board \_\_\_\_\_

Nevada driller's license number issued by the 1868-M  
 Division of Water Resources, the on-site driller \_\_\_\_\_

Signed Joseph E. Myhren, Jr.  
 By driller performing actual drilling on site or contractor \_\_\_\_\_

Date 6-3-97