

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 71707-71731
 Permit No. 100
 Basin 100
 NOTICE OF INTENT NO. 36895

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Roston Company, L.L.C. ADDRESS AT WELL LOCATION Reno Parks Blvd - 1450 Mud Springs Road
 MAILING ADDRESS 300 Carlsbad Village Drive
Carlsbad, Ca 92008

2. LOCATION NE 1/4 NE 1/4 Sec. 20 T. 21N N/S R. 18 E MDB+M County Cold Springs Valley Waste Water Treatment Plant
 PERMIT NO. DWPWA 96373 DEW-009 A, B Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED DW-19 4. PROPOSED USE dewater 5. WELL TYPE

New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other Destruction Municipal/Industrial Monitor Stock Air Other Bucket Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Purpose of Report -				
Destroy 23 Temporary Dewatering Wells -				
All casings extracted, allowing the gravel filter to drop to 6' or more - at least 2' below static water level. Those that did not drop the required depth were dug out with a small bucket backhoe - We pumped the static water level down on each well and filled with 5 sack grout to the existing surface grade.				
The above is all xxx in accordance with a letter dated May 16, 1997 from Thomas K. Gallagher, P.E. Hydraulic Engineer III				

8. WELL CONSTRUCTION

Depth Drilled..... Feet Depth Cased..... Feet

HOLE DIAMETER (BIT SIZE)

From	To
30 Inches	40 Feet
..... Inches Feet
..... Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
XXXX				
XXXX				

Perforations:

Type perforation.....

Size perforation.....

From..... feet to..... feet

Surface Seal: Yes No Seal Type:

Depth of Seal.....

Placement Method: Pumped Poured Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No

From..... feet to..... feet

9. WATER LEVEL

Static water level: 3.8 feet below land surface

Artesian flow..... G.P.M. P.S.I.

Water temperature..... °F Quality.....

Date started 5-29-97, 19.....

Date completed 5-29-97, 19.....

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Joseph E. Myhren, Jr. Contractor

Address 801 Northport Drive W. Sacramento, Ca. 95691 Contractor

Nevada contractor's license number 0044407 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1868-M

Signed Joseph E. Myhren, Jr. By driller performing actual drilling on site or contractor

Date 6-3-97