WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 11730
Permit No.
Basin 158

NOTICE OF INTENT NO. 32378

1. OWNER JOSEPH RAND.
MAILING ADDRESS EUREKA NEV. 89316.
ADDRESS AT WELL LOCATION DIAMOND VALLEY 11TH ST.
2. LOCATION SE ¼ NE ¼ Sec. 11 T. 21 N R. 53 E. EUREKA County
PERMIT NO. 21428 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	2	2
Sand Gravel		2	46	44
CLAY		46	48	2
CLAY BROWN & BLACK		48	100	52
BLACK GRAVEL		100	107	7
CLAY		107	109	2
Sand G.		109	115	6
CLAY		115	129	14
Sand GRAVEL	34	129	163	34
CLAY		163	168	5
Sand GRAVEL	14	168	182	14
CLAY		182	188	6
Sand GRAVEL	6	188	194	6
CLAY		194	205	11
SAND GRAVEL	9	205	214	9
FINE SAND.	9	214	223	9
SAND GRAVEL	6	223	229	6
CLAY		229	234	5
SAND GRAVEL	15	234	249	15
CLAY		249	259	10
SAND GRAVEL	2	259	261	2
CLAY		261	275	14
SAND GRAVEL	4	275	279	4
CLAY		279	281	2
SAND GRAVEL	3	281	284	3
CLAY WITH		284	295	11
SOME SAND				

Date started 4-25, 1998
Date completed 5-6, 1998

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1500	10'	2

8. WELL CONSTRUCTION
Depth Drilled 295 Feet Depth Cased 295 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
27 Inches	TOP Feet	295 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		¼	TOP	295

Perforations:
Type perforation ROSCOE MOSS
Size perforation ⅛"
From 135 feet to 295 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From TOP feet to 295 feet

9. WATER LEVEL
Static water level 68' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WALTER PLASKETT (Contractor)
Address BOX 10 (Contractor)
EUREKA NEV. 89316
Nevada contractor's license number issued by the State Contractor's Board 11882
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 635
Signed James E. Hull (By driller performing actual drilling on site or contractor)
Date 5-20-98

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627