

OFFICE USE ONLY
 Log No. 71740
 Permit No. _____
 Basin 179

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33052

1. OWNER James L. Canterbury ADDRESS AT WELL LOCATION 1 mile east of Ely, Nevada
 MAILING ADDRESS 989 Lyons Avenue Ely, Nevada 89301

2. LOCATION SW 1/4 SW 1/4 Sec 13 T. 16 N 3 R. 63 E White Pine County
 PERMIT NO. _____ Parcel 4 APN 10-790-01 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Water Sand & Gravel	x	5	15	10
Clay & Gravel		15	35	20
Water Sand & Gravel	x	35	40	5
Clay & Gravel		40	55	15
Clay & Water Sand	x	55	95	40
Clay		95	105	10
Water Sand Gravel & Clay	x	105	110	5
Clay		110	120	10

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	120

Perforations: Factory
 Type perforation _____
 Size perforation 1/8" x 2 1/2" 6 rows
 From 60 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured _____
 Gravel Packed: Yes No
 From 50 feet to 120 feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 52 °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc.
 Address 557 Ely Avenue Ely, NV 89301
 Nevada contractor's license number 14790 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 641 Division of Water Resources, the on-site driller.
 Signed Jarrod D. Christiansen By driller performing actual drilling on site or contractor
 Date July 28, 1997

Date started July 17, 1997
 Date completed July 18, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>98</u>	<u>1</u>

RECEIVED
 97 JUL 30 AM 11:13
 STATE ENGINEER'S OFFICE