WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71765
Permit No.
Basin 212

NOTICE OF INTENT NO. 14894

1. OWNER Scott Loughridge
MAILING ADDRESS
ADDRESS AT WELL LOCATION vacant

2. LOCATION SE ¼ NE ¼ Sec. 25 T. 19S N/S R. ~~60~~ 59 E. Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 126-25-601-005 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Gravel | | 0 | 60 | |
| Cemented Gravel | | 60 | 95 | |
| Gravel | | 95 | 540 | |
| Gravel & Water | xx | 540 | 560 | |
| Gravel | | 560 | 660 | |
| Gravel & Water | xx | 660 | 700 | |

Date started 6/5/98, 19
Date completed 6/18/98, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 700 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 1/4 | Inches | 0 Feet | 70 Feet |
| 10 5/8 | Inches | 70 Feet | 700 Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | +1 | 700 |

Perforations:
Type perforation Factory
Size perforation 3/16 x 8 row
From 660 feet to 680 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 464 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick Contractor
Address 5360 Bonita Vista Contractor
Las Vegas, Nev. 89129
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed By driller performing actual drilling on site or contractor
Date 6-18-98

DCS FILED JUN 25 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627