



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32837

1. OWNER BRUCE LARSON ADDRESS AT WELL LOCATION 1/4 MILE SOUTH ON LARSON BLANE ON LEFT SIDE OF ROAD.
 MAILING ADDRESS PO Box 1920 ROUND MTN NEV 89045

2. LOCATION SW 1/4 SW 1/4 Sec. 4 T. 10 N/S R. 43 E. NYE County
 PERMIT NO. 12-461-22 Parcel No. LARSON Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BRN CLAY		0	5	5
LARGE GRAVEL		5	24	19
BRN CLAY		24	34	10
SMALL GRAVEL & CLAY MIX		34	46	12
GRAY CLAY		46	52	6
SAND		52	57	5
TAN CLAY		57	90	33
SMALL GRAVEL & SAND		90	96	6
TAN CLAY		96	111	15
MEDIUM GRAVEL	X	111	125	14
DARK BRN CLAY		125	145	20
BOULDERS & LARGE GRAVEL	X	145	163	18
GRAY CLAY		163	165	2

8. WELL CONSTRUCTION
 Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
Inches	Feet	Inches	Feet
<u>10 5/8</u>	<u>0</u>	<u>5 0</u>	<u>5.0</u>
<u>8 3/4</u>	<u>5.0</u>	<u>16.5</u>	<u>16.5</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>7.2</u>	<u>14.5</u>

Perforations:
 Type perforation MILLED
 Size perforation 3 1/8 DOUBLE ROW
 From 14.5 feet to 16.5 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
X ENVIRO PLUG

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WOYTEK DRILLING CO. INC. Contractor
 Address 2220 STONE DRIVE Contractor
RENO NEV 89511
 Nevada contractor's license number issued by the State Contractor's Board 024521A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
 Signed Thomas M Harris
 By driller performing actual drilling on site or contractor
 Date 6-16-98

Date started 6-15, 1998
 Date completed 6-16, 1998

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>60</u>		<u>4 HRS</u>
<u>PUMP SHOULD BE SET AT 100'</u>		