WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71782
Permit No.
Basin 85

NOTICE OF INTENT NO. 37763

1. OWNER Ed Alexander
MAILING ADDRESS 6404 Aleute Ct.
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ NW ¼ Sec. 19 T 21 N/S R 21 E AST Washoe County
PERMIT NO. (Issued by Water Resources) 76-370-44 (Parcel No.) Parcel # (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown D.G.		0	5	5
Brown fine sand		5	13	8
Brown D.G.		13	20	7
Light brown clay stone		20	35	15
Brown & black clay stone		35	50	15
Brown & black volcanic rock		50	70	20
Brown clay		70	90	20
Brown clay w/multi colored course sand		90	100	10
green clay stone w/multi colored course sand		100	145	45
Black & gray volcanic rock w/multi colored course sand.	X	145	200	55
Multi colored course sand & gravels	X	200	280	80
T.D. 280'				

Date started June 9, 19 98
Date completed June 10, 19 98

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2 hrs

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-5/8 Inches	0 Feet	280 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.225	+1½	280

Perforations:
Type perforation Factory Sawed
Size perforation 3/32 x 3
From 240 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 280 feet to 50 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service Inc. (Contractor)
Address P.O. Box 60130 (Contractor)
Reno, Nv 89506
Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2066
Signed (By driller performing actual drilling on site or contractor)
Date June 17, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627