WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71812
Permit No.
Basin 212

NOTICE OF INTENT NO. 16661

1. OWNER Las Vegas Paite Tribe
MAILING ADDRESS 1 Pauite Drive
Las Vegas, NV 89106

ADDRESS AT WELL LOCATION Snow Mtn. REservation

2. LOCATION NE ¼ NE ¼ Sec. 25 T. 18 N/S R. 59 E. Clark County
PERMIT NO. Waiver No. R-1019 (Issued by Water Resources) | Parcel No. 540-200-12 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Gravel & boulders, "fill" | | 1 | 80 | 80 |
| Brown clay & gravel | | 80 | 110 | 30 |
| Brown clay | | 110 | 140 | 30 |
| Brown clay & gravel | | 140 | 170 | 30 |
| Brown clay | | 170 | 185 | 15 |
| Brown clay & gravel | | 185 | 215 | 30 |
| Brown clay | | 215 | 265 | 50 |
| Medium hard rock | | 265 | 360 | 95 |
| quartz-salt & peppers | | | | |
| color's sedimentary rock | | | | |

Date started June 15, 19 98
Date completed July 1, 19 98

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 310 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 9 7/8 | Inches | 1 Feet | 360 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6" | PVC | .280 | 1 | 310 |
| | | | | |

Perforations:
Type perforation slotted screen
Size perforation 020
From 270 feet to 310 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 310 feet

9. WATER LEVEL
Static water level 280.6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thomspon Drilling Co., Inc. (Contractor)
Address 7227 Hauck Street (Contractor)
Las Vegas, NV 89118

Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010

Signed Richard K. Thompson
By driller performing actual drilling on site or contractor
Date July 2, 1998

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627