WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 71816
Permit No.
Basin 162

NOTICE OF INTENT NO. 18037

1. OWNER Gary Robb
MAILING ADDRESS 3751 S. Tahachapi
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
3751 S. Tahachapi

2. LOCATION SW 1/4 SW 1/4 Sec. 31 T 20S N/S R 54E E Nye County
PERMIT NO. (Issued by Water Resources) 41-143-01 (Parcel No.) Calvada Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown sandy loam		0	22	22
brown sandy loam		22	24	2
grey calache		24	44	20
brown calache		44	48	4
See next line		48	55	7
brown sandy loam/brown calache strings				
brown calache		55	76	21
brown calache	x	76	83	7
brown calache	x	83	84	1
brown calache	x	84	106	22
brown calache	x	106	110	4
grey calache	x	110	112	2
white calache	x	112	115	3
beige calache	x	115	120	5
grey clay	x	120	138	18
brown clay	x	138	140	2

DCNR/DWR Received JUL 13 1998 Las Vegas Office

Date started 7/2/98, 19__
Date completed 7/2/98, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5	na	.50

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	140

Perforations:
Type perforation saw cut
Size perforation .188
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Gary Strickland (By driller performing actual drilling on-site or contractor)
Date 7-7-98