

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17747

1. OWNER **Debbie and Bob Bogenholm** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **2951 E. Deadwood** **2951 E. Deadwood**
Pahrump, NV 89048

2. LOCATION **SE** 1/4 **NE** 1/4 Sec. **36** T **20S** N/S R **53E** E **Nye** County
 PERMIT NO. **41-061-11** **Calvada Valley** Subdivision Name
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown sandy loam		0	10	10
brown sandy loam		10	17	7
brown sandy loam		17	27	10
brown calache		27	36	9
brown calache		36	58	22
brown calache		58	61	3
brown sandy loam		61	74	13
brown sandy loam	x	74	78	4
brown calache	x	78	84	6
brown sandy loam & gravel	x	84	96	12
brown sandy loam and gravel	x	96	104	8
brown calache	x	104	118	14
brown calache	x	118	140	22
brown sandy loam	x	140	155	15

8. WELL CONSTRUCTION
 Depth Drilled **155** Feet Depth Cased **155** Feet

HOLE DIAMETER (BIT SIZE)
 From To
11 Inches **0** Feet **155** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	155

Perforations:
 Type perforation **Saw Cut**
 Size perforation **.188**

From **115** feet to **155** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **155** feet


9. WATER LEVEL
 Static water level **74** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cold** °F Quality **good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Strickland Construction Co., Inc.** Contractor
 Address **2301 Winery Road, Suite 2** Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board **40277**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2086**

Signed *[Signature]*
 By driller performing actual drilling on-site or contractor
 Date **7-9-98**



Date started **7/2/98**, 19____
 Date completed **7/2/98**, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	.5	na	.50

