

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 71831
 Permit No. 62346
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17746

1. OWNER Lombardi/Antonacci ADDRESS AT WELL LOCATION 2221 N. Hwy 160
 MAILING ADDRESS 2221 N. Hwy 160 2221 N. Hwy 160
Pahrump, NV 89048

2. LOCATION SW 1/4 SE 1/4 Sec. 34 T 19S N/S R 53E E Nye County
 PERMIT NO. 62346 27-401-29 Nye County
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown sandy loam and gravel		0	20	20
See next line		20	26	6
brown sandy loam and calache strings				
See next line		26	47	21
white calache and grey calache strings				
brown calache		47	70	23
See next line	x	70	87	17
brown sandy loams and calache strings				
brown calache	x	87	98	11
brown calache and rock	x	98	103	5
brown calache and rock	x	103	115	12
brown calache and gravel	x	115	120	5
brown calache and rock	x	120	132	12
brown sandy loam and rock	x	132	138	6
See next line	x	138	162	24
brown sandy loam rock and gravel				
brown sandy loam and rock	x	162	189	27
brown sandy loam and rock	x	189	205	16

8. WELL CONSTRUCTION
 Depth Drilled 205 Feet Depth Cased 205 Feet

HOLE DIAMETER (BIT SIZE)
 From To
13 Inches 0 Feet 205 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>205</u>


Perforations:
 Type perforation torch cut
 Size perforation 3/16

From 162 feet to 205 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 205 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good



Date started 6/24/98 .19
 Date completed 6/24/98 .19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>.5</u>	<u>na</u>	<u>.50</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 7-9-98

